

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 124688
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33128

1. OWNER Dale Shemp ADDRESS AT WELL LOCATION
 MAILING ADDRESS P.O. Box 922 6150 E. Kent Street 36D7°10.46'N 115D54°8.7'W NAD 83
Pahrump, NV 89048

2. LOCATION S/W 1/4 S/W 1/4 Sec. 15 T 21S N/S R 54E E Nye County
 PERMIT NO. 45-161-08 Kellogg Hillside Estates Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown loam</u>		<u>0</u>	<u>64</u>	<u>64</u>
<u>See next line</u>		<u>64</u>	<u>66</u>	<u>2</u>
<u>brown loam with caleche strings</u>				
<u>brown loam</u>		<u>66</u>	<u>78</u>	<u>12</u>
<u>See next line</u>	<u>x</u>	<u>78</u>	<u>142</u>	<u>64</u>
<u>brown loam with caleche strings</u>				
<u>brown loam with gravel</u>	<u>x</u>	<u>142</u>	<u>144</u>	<u>2</u>
<u>See next line</u>	<u>x</u>	<u>144</u>	<u>240</u>	<u>96</u>
<u>brown loam with caleche strings</u>				

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240+1 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation sawcut
 Size perforation .188
 From 200 feet to 240 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 80 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2085
 Signed _____ By driller performing actual drilling on-site of contractor
 Date 5-30-15

Date started 4/29/15 _____ 19____
 Date completed 4/29/15 _____ 18____

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)

36.1196083 NAD
 -115.901562 2A