STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124671
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34614
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME NICOL R. MAURY
MAILING ADDRESS 3134 E. TRUENO RD.
HENDERSON, NV 89014

DETAILED ADDRESS AT WELL LOCATION
1341 S. BANNAVITCH ST. PAHRUMP, NV
Subdivision Name: Wagon Wheel Ranchos Lot:28 *County:* NYE

2. PLS LOCATION SW ¼ NW ¼ 24 Sec 20-S N/S 52 E
PERMIT/WAIVER NO. 028-492-05
Issued by Water Resources *Current Parcel No.*

Latitude N36°11.969' UTM E 2525' ☐ NAD 27
Longitude W116°05.102' UTM N 13' ☒ NAD 83 (WGS 84)

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / GM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Surface			0	4
Gray Clay/Granulated Caliche			4	31
Brown Clay			31	87
Brown Clay/Caliche			87	93
Brown Clay			93	106
Brown Clay/Caliche		X	106	118
Brown Clay		X	118	150
Brown Clay/Caliche		X	150	180

Date started: 2-Dec , 20 15
Date completed: 4-Dec , 20 15

9. CONSTRUCTION
Depth Drilled: 180 Feet Depth Cased: 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Well Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	0	180

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☒ Concrete Grout	0	to 50	☐ Pumped	☒ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to 180	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/4" width 3" long

From	Feet	To	Feet
140		180	

7. WATER QUALITIES
Static water level: 76 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 64 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Jim Pike Well Drilling LLC
Contractor
Address P O Box 56 Pahrump, NV 89041
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1324

Signed: Jim Pike
By driller performing actual drilling on site or contractor
Date: 12/08/15

DENR/DWR/SNPC RECEIVED DEC 11 2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1995646
-116.0341436
NAD 27