STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124672
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37328

1. OWNER MATTHEW & TANA BOLIN
MAILING ADDRESS 134 BELL LN
REEDSPORT OR 97467

ADDRESS AT WELL LOCATION 1601 S ADAMS ST
PAHRUMP
Subdivision Name: JNLAND DEVELOPMENT II County: NYE

2. LOCATION NE ¼ SE ¼ Sec 20 T 20S N/S R 53 E
PERMIT/WAIVER No. 36-422-15
Issued by Water Resources Parcel No.

Latitude N36°11'46.7" Longitude W116°02'10.8"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING		0	140	-140
CLAY & GRAVEL		140	165	-25
CALICHIE	WB	165	195	-30
CLAY & GRAVEL		195	210	-15
CALICHIE	WB	210	230	-20
CLAY		230	240	-10

NDNR/DWR/SNBO
RECEIVED
JAN 04 2016

Date started: 23-Dec , 20 15
Date completed: 23-Dec , 20 15

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING 8	Inches	0	Feet	140	Feet
7-7/8	Inches	140	Feet	240	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	240

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 140 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

EXISTING Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 6 to 240 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 83 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed (By driller performing actual drilling on site or contractor)
Date 12/28/2015

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY

36.1963447
-116.035473
NAD 27