

RECEIVED

2016 MAR 16 PM 1:51

PRINT OR TYPE IN BLACK INK ONLY

DO NOT WRITE ON BACK

STATE ENGINEERS OFFICE

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 124755
Permit No.
Basin No. 131

NOTICE OF INTENT NO. 73838
WELL NAME (if applicable): CM-5

1. OWNER/CLIENT NAME Newmont Gold
MAILING ADDRESS 1655 Mountain City Hwy
Elko, NV 89822

DETAILED ADDRESS AT WELL LOCATION Phoenix Mine
Battle Mountain, NV 89820
Subdivision Name County Lander

2. PLS LOCATION SW 1/4 SW 1/4 9 Sec 30 NS 43 E
PERMIT/WAIVER NO.
Issued by Water Resources Current Parcel No.

Latitude N 40° 28.960 UTM E
Longitude W 117° 09.013 UTM N
NAD 27
NAD 83/WGS 84

3. WORKED PERFORMED
New Well Deepen: Orig WL#
Replacement: Original well log #
Recondition: Original well log #

4. PROPOSED USE
Domestic Irrigation Monitor
Mining / Dewater Corn / Ind Stock
Test / Other Mun / QM Rec

5. WELL TYPE
Auger Rotary RVC
Air Mud Sonic
Other

LITHOLOGIC LOG table with columns: Material Encountered, Lost Circ., Water Strata, From, To. Includes entries like Top soil, gravels sands, Consolidated sand and gravels, etc.

9. INSTRUCTION
Depth Drilled: 374 Feet
Depth Cased: 358 Feet
HOLE DIAMETER (BIT SIZE) table with columns: From, To, Inches, Feet.

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet).

ANNULAR MATERIALS
Sanitary Seal Yes No
Neat Cement +1 to 75 Pumped Poured
Cement Grout to Poured Poured
Concrete Grout to Poured Poured
Bentonite Chips 75 to 80 Pumped Poured
Gravel Pack (> 0.2 in.) 80 to 374 Pumped Poured
Sand Pack (< 0.2 in.) to Poured Poured
Other, explain: to Poured Poured

PERFORATIONS:
Type of perforation: SS Louver
Size of perforation: 0.125 slot
From 100 Feet To 300 Feet
From 320 Feet To 358 Feet

Date started: 26-Jan 20 16
Date completed: 12-Feb 20 16

7. WATER QUALITIES
Static water level: 123 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 40 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA table with columns: Test Method (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Recorded Time (Hours).

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Hydro Resources-West, Inc. Contractor
Address: 4975 W. Winnemucca Blvd., Winnemucca, NV 89445 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 56797
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2289
Signed: Michelle Strother
Date: 2-18-16