STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124828
Permit No.
Basin No. 108

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73316
WELL NAME (If applicable):

1. OWNER/CLIENT NAME: DICK TIJSSELING
MAILING ADDRESS: 35 MAC KENZIE LANE, YERINGTON, NV 89447

DETAILED ADDRESS AT WELL LOCATION: 35 MAC KENZIE LANE, YERINGTON, NV 89447
Subdivision Name: County: Lyon

2. PLS LOCATION: SE ¼ NE ¼ 11 Sec 12 N/S 25 E
PERMIT/WAIVER NO. (Issued by Water Resources): Current Parcel No.: 012-281-20
Latitude: 38.919702*N UTM E: ☐ NAD 27
Longitude: 119.145307*W UTM N: ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# N/A
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
OLD 6 5/8 WELL			0	80
COURSE GRAVELS			80	160
BROWN CLAY			160	210
BROWN SILTY SANDS			210	245
DG SANDS AND GRAVELS		XXX	245	300

NAD 27
38.919702°N
119.145307°W

RECEIVED 2016 MAR -7 AM 11:46 STATE ENGINEERS OFFICE

Date started: 9-Feb, 20 16
Date completed: 12-Feb, 20 16

9. INSTRUCTION
Depth Drilled: 220' Feet Depth Cased: 220' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	80	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	4.26	.216	60	300

ANNULAR MATERIALS
Sanitary Seal x ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	Feet	To	Feet
260		300	

7. WATER QUALITIES
Static water level: 85 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 64° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	85	3 HOURS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address: 20 KIT KAT DRIVE CARSON CITY, NV 89706 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: (By driller performing actual drilling on site or contractor)
Date: 2/28/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.