STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 124841
Permit No.
Basin No. 064

NOTICE OF INTENT NO. 74219
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Jay Wintle
MAILING ADDRESS 810 Sheep Creek Rd.
Battle Mountain NV.

DETAILED ADDRESS AT WELL LOCATION 690 Yellow Brick Rd.
Battle Mountain NV
Subdivision Name: *County.* Lander

2. PLS LOCATION SE ¼ SE ¼ 14 Sec 32 N/S 44 E
PERMIT/WAIVER NO 010-280-2136
Issued by Water Resources *Current Parcel No.*

Latitude ~~N40.6395855~~ UTM E ☐ NAD 27
Longitude ~~W116.9797207~~ UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Sand		No	0	6
Coarse gravel,cobbles sand clay		No	6	30
Hard Brown Clay sand		yes	30	120

Date started: ~~3 Apr~~ 3-3 , 20 16
Date completed: ~~03/05/16~~ 3-12 , 20 16

RECEIVED
2016 APR 14 PM 1:45
STATE ENGINEER'S OFFICE

7. WATER QUALITIES
Static water level: 35 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	N/A	5

NAD 27
40.641757
116.980779

9. CONSTRUCTION
Depth Drilled: 120 Feet Depth Cased: 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8"	PVC	Sched 40	20	120

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to 20	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to 50	☐ Pumped	☒ Poured
☒ Gravel Pack [> 0.2 in.]	50	to 120	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2

From	To
80 Feet	120 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd Winnemucca NV
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board.* 76778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1563
Signed:
By driller performing actual drilling on site or contractor
Date. 3-30-16

(Rev 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.