STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 124842
Permit No.
Basin No. 064

NOTICE OF INTENT NO. 74216
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Jay Wintle
MAILING ADDRESS 810 Sheep Creek Rd.
Battle Mountain NV.

DETAILED ADDRESS AT WELL LOCATION 675 Yellow Brick Rd.
Battle Mountain NV
Subdivision Name:

2. PLS LOCATION SE ¼ SE ¼ 14 Sec 32 N/S 44 E
PERMIT/WAIVER NO. 010-280-31
Issued by Water Resources — Current Parcel No

County: Lander
Latitude N40*38'30.150 UTM E
Longitude W116*58'54.170 UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand		No	0	6
Coarse gravel,cobbles sand clay		No	6	30
Hard Brown Clay		yes	30	120

9. CONSTRUCTION
Depth Drilled: 120 Feet Depth Cased: 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8"	PVC	Sched 40	20	120

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to 20	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to 50	☐ Pumped	☒ Poured
☒ Gravel Pack [> 0.2 in.]	50	to 120	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2
From 80 Feet To 120 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

Date started: ~~1-Feb~~ 2-29 , 20 16
Date completed: 03/05/16 , 20 16

7. WATER QUALITIES
Static water level: 35 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	N/A	5
	NAD 27	
	40.641797	
	116.980779	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd Winnemucca NV (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 76778
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1563
Signed: (By driller performing actual drilling on site or contractor)
Date: 3-31-16

RECEIVED 2016 APR -4 PM 1:45 STATE ENGINEER'S OFFICE

(Rev 12-13)
USE ADDITIONAL SHEETS IF NECESSARY
pg. of pg.