STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 124843
Permit No.
Basin No. 085

1. OWNER/CLIENT NAME Jason Fish
MAILING ADDRESS 2965 Shady Creek Ct
Reno, NV 89523

NOTICE OF INTENT NO. 73205
WELL NAME (if applicable)
DETAILED ADDRESS AT WELL LOCATION 2125 Pancho Villa Court
Sparks, NV 89441
Subdivision Name Spanish Springs Ranches, Unit # 2 County Washoe

2. PLS LOCATION NW ¼ SE ¼ 31 Sec 21 N/S 21 E
PERMIT/WAIVER NO DOM 16-1 (Issued by Water Resources) 076-391-58 (Current Parcel No)
Latitude 39.642.00 Longitude -119.67452
UTM E UTM N
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
■ Air ■ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Dirt & Rock			0	10
Brown Clay			10	20
Brown Clay & Rock			20	80
Brown Clay & Sand			80	120
Sand & DG			120	140
Sand & Gravel			140	200
Sand, Gravel, Brown Clay			200	220
Sand & Gravel		X	220	240
Mixed Sand & Grey Clay			240	297
Course Mixed Sands & Grey Clay			297	360
Multi-Colored Fractured Rock			360	380
Multi-Coloered Course Sand		X	380	392
Red Clay			392	394
T.D. 394				

Date started 17-Mar , 20 16
Date completed 22-Mar , 20 16

7. WATER QUALITIES
Static water level: 180 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	20		4.5 Hours
		NAD 27	
		39.642090	
		119.673501	

9. INSTRUCTION
Depth Drilled: 394 Feet Depth Cased: 394 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	55	Feet
8 1/2	Inches	55	Feet	394	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	0.188	+2	394

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
■ Cement Grout	0	to	55	☐ Pumped	■ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in]	55	to	394	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Factory
Size of perforation: 3/32 x 3

From		To	
234	Feet	254	Feet
374	Feet	394	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address P.O. Box 60130 Reno, Nevada 89506 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (for-site driller) 2382
Signed [signature] (Well Driller or Responsible Employee)
Date 3-23-16

(Rev 12-13)

USE ADDITIONAL SHEETS IF NECESSARY