STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124863
Permit No.
Basin 099

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74544

1. OWNER George & Kathy DeJaniver
MAILING ADDRESS 1204 Giovanni St.
St. Antioch, CA 94509

ADDRESS AT WELL LOCATION 25 Thoroughbred Circle
Reno, NV 89508
Subdivision Name: County: Washoe

2. LOCATION SW¼NW¼ Sec27T23N/S R18E
PERMIT/WAIVER NO. 078-071-09
Issued by Water Resources Parcel. No.

Latitude 39.831278 UTM E ☐ NAD 27
Longitude -119.957384 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG, Brown Clay & Sands	X	0	348	348
Granite	X	348	360	12

NAD 27
39.831371
119.956352

Washoe Co. Permit #WL150143

Date started: 3/7, 20 16
Date completed: 3/10, 20 16

9. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	360	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	360

Perforations:
Type of perforation Factory
Size of perforation .060 Double perf.
From 360 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 105.5 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 105 to 360 ☐ Pumped ☒ Poured
Type: 1/4x1/8
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 200' feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: 56 °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	30		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed
By driller performing actual drilling on site or contractor
Date 3/11/16