STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124872
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73559
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Craig Young
MAILING ADDRESS 1307 Myers Dr Gardnerville
DETAILED ADDRESS AT WELL LOCATION 1307 Myers
Subdivision Name: County: Douglas

2. PLS LOCATION 3 E¼ NW ¼ 05 Sec 12 N/S 21 E
PERMIT/WAIVER NO. 1221.05.001.066 *Issued by Water Resources* *Current Parcel No.*
Latitude 39.933465 UTM E ☐ NAD 27
Longitude 119.653959 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 7
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Sand (gravel)			77	95	
Clay			95	106	
Cobbles			106	181	
Sand. chip Rock			181	202	

Date started: 3-16, 20 16
Date completed: 3-18, 20 16

RECEIVED 2016 APR -8 PM 2:01 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled: 202 Feet Depth Cased: 202 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8 Inches		77 Feet	202 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.13	.188	62	202

PERFORATIONS:
Type of perforation: factory cut
Size of perforation: .060 X 4
From 202 Feet To 162 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal N/A to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 98 Feet below land surface
Artesian Flow: NO G.P.M. NO P.S.I.
Water Temperature: 64 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air	357		4
		NAD 27	
		38.933556	
		119.652853	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Address P.O. Box 1255 Carson City, NV 89702
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 46499A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2134
Signed: *By driller performing actual drilling on site or contractor*
Date: 3-25-16

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY
(O) 627

Deepening unknown well log