STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124873
Permit No.
Basin No. 087

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74422
WELL NAME (If applicable):

1. OWNER/CLIENT NAME: Marcia Murray
MAILING ADDRESS: 5645 Melarky way Reno NV 89511

DETAILED ADDRESS AT WELL LOCATION: 0 Rock Farm RD
Subdivision Name: County: Washoe

2. PLS LOCATION: pw ¼ SW se ¼ 26 Sec. 18 N/S 19 E
PERMIT/WAIVER NO. 150-250-28
Issued by Water Resources Current Parcel No

Latitude 39 23 32.06 UTM E ☐ NAD 27
Longitude 119 48 52 .20 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand- clay			0	23
Gravel			23	68
Clay			68	74
Sand & clay			74	93
Black Frac rock			93	213
clay			213	222
Black rock			222	236
Sand-clay			236	297
Frac rock			297	361
Clay			361	366
Frac granite- sand			366	409

Date started: 28-Feb , 20 16
Date completed: 5-Mar , 20 16

7. WATER QUALITIES
Static water level: 245 Feet below land surface
Artesian Flow: no G.P.M. no P.S.I.
Water Temperature: 61 ° Fahrenheit
Water Quality: clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
45+		4
	NAD 27	
	39.392328	
	119.813478	

9. INSTRUCTION
Depth Drilled: 409 Feet Depth Cased: 409 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	345	Feet
6	Inches	345	Feet	409	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	345
5	12	.188	269	409

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	0	to 58	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: .090 X 4"

From	409	Feet	To	389	Feet
From	369	Feet	To	349	Feet
From	345	Feet	To	325	Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Blain Drilling and Pump INC (Contractor)
Address: Po 1255 CC NV 89702 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2321
Signed: C. Robinson (By driller performing actual drilling on site or contractor)
Date: 3/25/2016

RECEIVED 2016 APR -8 PM 2:01 DIVISION OF WATER RESOURCES

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.