STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124899
Permit No.
Basin No. 087

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74266
WELL NAME (If applicable): well#2

1. OWNER/CLIENT NAME Reno City of
MAILING ADDRESS PO BOX 1900 C/O Property Management Reno NV 89505

DETAILED ADDRESS AT WELL LOCATION 6800 Pembroke Dr., Reno NV
Subdivision Name. County: Washoe

2. PLS LOCATION NW ¼ NW ¼ 27 Sec 19N N/S 20 E
PERMIT/WAIVER NO. DW -120 (Issued by Water Resources) 021-160-44 (Current Parcel No.)

Latitude 39. 29' 24.46 UTM E ☐ NAD 27
Longitude - 119.43' 58.94 UTM N x NAD 83/WGS 84

3. WORKED PERFORMED
x New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
x Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
x Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
top soil - silty sand			0	3
piet			3	8
gray blue clay			8	15

NAD 27
39.490236°N
119.732036°W

Date started. 18-Mar , 20 16
Date completed: 18-Mar , 20 16

7. WATER QUALITIES
Static water level: 4 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 15 Feet Depth Cased: 15 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	15	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	SCH 40	0	15

ANNULAR MATERIALS
Sanitary Seal x Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
Bentonite Chips	4	to 6	☐ Pumped	x Poured
x Gravel Pack [> 0.2 in.]	0	to 15	☐ Pumped	x Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: machine slot
Size of perforation: 0.032

From	0	Feet	To	~~10~~ 15 Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Viking Drillers, Inc (Contractor)
Address 5950 Granite Lake Drive, Granite Bay, CA 95746 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0034680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2361

Signed: (By driller performing actual drilling on site or contractor)
Date. 4/20/16

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.