STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124943
Permit No.
Basin No. 104

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74960
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME 5 SEAT INVESTMENTS
MAILING ADDRESS 8001 HWY 50 EAST
CARSON CITY, NV 89706

DETAILED ADDRESS AT WELL LOCATION 8001 HWY 50 EAST
CARSON CITY, NV 89706
Subdivision Name: *County:* Carson City

2. PLS LOCATION NW ¼ SE ¼ 36 Sec 16 N/S 20 E
PERMIT/WAIVER NO. *Issued by Water Resources* 008-611-39 *Current Parcel No*

Latitude 39.207178*N UTM E ☐ NAD 27
Longitude 119.683178*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# N/A
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
OPLD 8 5/8 WELL			0	160
HARD OBSIDIAN GRANITE			160	210
VERY HARD SLATE			210	220
FRACTURED OBSIDIAN GRAVEL		XXX	220	260

RECEIVED 2016 APR 12 AM 8:49 STATE ENGINEERS OFFICE

Date started: 28-Mar , 20 16
Date completed: 1-Apr , 20 16

9. INSTRUCTION
Depth Drilled: 100 Feet Depth Cased: 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	160	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.96	.216	60	260

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	200	Feet	To 260	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet

7. WATER QUALITIES
Static water level: 85 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 56* ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	85	3 HOURS
	NAD 27	
	39.207267	
	119.682166	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. *Contractor*
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 0055548
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1905
Signed: *By driller performing actual drilling on site for contractor*
Date: 4/8/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepening unknown well log