STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124947
Permit No.
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73319
WELL NAME (If applicable):

1. OWNER/CLIENT NAME STEPHEN AND LORETTA MARTI
MAILING ADDRESS 1286 CENTERVILLE LANE
GARDNERVILLE, NV 89410

DETAILED ADDRESS AT WELL LOCATION 1286 CENTERVILLE LANE
GARDNERVILLE, NV 89410
Subdivision Name. County: Douglas

2. PLS LOCATION NW ¼ SW ¼ 4 Sec. 12 N/S 20 E
PERMIT/WAIVER NO. 1220-04-002-003
Issued by Water Resources Current Parcel No

Latitude 38.93114*N UTM E ☐ NAD 27
Longitude 119.748878*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # N/A
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
COBBLES AND BOULDERS			0	75
HEAVEY GRAVELS			75	105
SMALL GRAVELS			105	140
FRACTURED GRAVELS		XXX	104	180

Date started: 1-Mar, 20 16
Date completed: 4-Mar, 20 16

7. WATER QUALITIES
Static water level: 26 Feet below land surface
Artesian Flow: G.P.M. 56* P.S.I.
Water Temperature: COLD ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25+	45	3 HOURS

NAD 27
38.391233
119.747868

9. INSTRUCTION
Depth Drilled: 180 Feet Depth Cased: 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	180
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	105	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	105	to	180	☐ Pumped	☐X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY MILL SLOT
Size of perforation: 0.032

From	Feet	To	Feet
140	Feet	180	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1905
Signed: Michael Hoek
By driller performing actual drilling on site or contractor
Date: 3/26/2016

RECEIVED 2016 APR 12 AM 8:49 STATE ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replacing unknown well log