STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No 124987
Permit No
Basin No 093

NOTICE OF INTENT NO. 73228
WELL NAME

1. OWNER/CLIENT NAME: Andrew Spence
MAILING ADDRESS: 1379 Antelope Valley Road, Reno, NV 89508

DRILLED ADDRESS AT WELL LOCATION: 2800 Antelope Valley Road, Reno, NV 89508
Subdivision Name: Red Rock Estates County: Washoe

2. THIS LOCATION: NW ¼ NE ¼ 14 22 19
PERMIT WAIVER NO: 079-481-43
Latitude: 39.77856 Longitude: -119.81614

3. WORKED PERFORMED
■ New Well ☐ Deepen Orig WL#
☐ Replacement Original well log #
☐ Recondition Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
■ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered			From	To
Sand & Dirt			0	20
Black & White DG			20	80
Green & Black DG			80	130
Black & White DG			130	150
Gray & White Granite			150	186
From 170'-180'				
Backfilled with cuttings,				
making sand.				
T.D. 170'				
Completed	21-Apr		20	16
Completed	22-Apr		20	16

7. WATER ENCOUNTERED
Static water level: 110 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	20+	140	2 Hours
		NAD 27	
		39.778652	
		119.815114	

9. INSTRUCTIONS
Depth Drilled: 186 Feet Depth Cased: 170 Feet

HOLE DIAMETER(S) SIZE

		From		To	
10 5/8	Inches	0	Feet	55	Feet
8 1/2	Inches	55	Feet	170	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	0.188	+3	170

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
■ Cement Grout	0	to 55	☐ Pumped	■ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in.]	55	to 170	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Factory
Size of perforation: 3/32 x 3

From	Feet	To	Feet
150	Feet	170	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge

Name: A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address: P.O. Box 60130 Reno, Nevada 89506 (Contractor)
Nevada contractor's license number as issued by the State Contractors Board: 35387C
Nevada well driller's license number as issued by the State Engineer: 2362
Signature: Larry Welch
Date: 4/27/2016

(Rev. 12-13)

USE ADDITIONAL SHEETS IF NECESSARY