STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No 124982
Permit No
Basin 200

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety
[illegible] NRS 534.170 [illegible] 340

NOTICE OF INTENT NO 71833

1. OWNER Tim Allison
MAILING ADDRESS 1591 E Los Cositos Street
Pahrump Nev 89048

ADDRESS AT WELL LOCATION 1/2 mile past Firehouse
1/4 mile west
Subdivision 0 County Lincoln

2. LOCATION 40 SW ¼ Sec 35 -2 R 69 E
PERMIT/WAIVER No. 0 006-241-71
SE Issued by Water Resources Parcel No

Latitude N 37° 59.052
Longitude W 114 13.253
UTM E
N

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Bearing	From	To	Thickness
Sand - boulders		0	90	90
Fractured Rock	X	90	150	100
Hard Rock		150	155	5

7' of 8" steel casing was grouted over 6" PVC at surface

Date started: 4-18-2016, 20
Date completed: 4-28-2016, 20

7. Water Level
Static water level: 75 feet below land surface
Artesian Flow: 0 G.P.M. P.S.I.
Water Temperature: cold °F
Quality: good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		2
	NAD 27	
	37.984238	
	114.220067	

9. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

CASING AMOUNT BY TYPE

		From		To	
11	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 1/2	PVC	Sch 40	0	155

Type of perforation Saw cut
Size of perforation 1/8 x 3"
From 105 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal [X] Yes [ ] No
[X] Neat Cement 0 to 150 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] 30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 100 to 155 [ ] Pumped [X] Poured
Type: 1/4" minus
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps
Contractor
Address HC61 Box 54 Hiko Nev 89017
Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site or ... 1191
Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 4-30-2016

USE ADDITIONAL SHEETS IF NECESSARY

SEPO 3-08