STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125008
Permit No. 86055T / 86056
Basin No. 167

NOTICE OF INTENT NO. 38895
WELL NAME (If applicable): CC Con #1

1. OWNER/CLIENT NAME: CC Construction Grading & Paving
MAILING ADDRESS: 5850 W. Desert Inn Rd, Las Vegas, NV 89146

DETAILED ADDRESS AT WELL LOCATION: Boulder Solar
Subdivision Name:

2. PLS LOCATION: SW ¼ NW ¼ 29 Sec 24 N 0 63 E
PERMIT/WAIVER NO. 86055T & 86056T (Issued by Water Resources) | 207-00-002-037 (Current Parcel No.)

County: Clark
Latitude 35.831245 UTM E
Longitude -114.971585 UTM N
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
■ Recondition: Original well log # 9305

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
■ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Remove fill from 12-inch casing			431	460
INSTALL 10-inch liner			+1.5	459
swabbed & airlifted to recondition existing well				

DCNR/DWR/SNBO RECEIVED MAY 26 2016

Date started: 5-May, 20 16
Date completed: 22-May, 20 16

7. WATER QUALITIES
Static water level: 264.5 Feet below land surface
Artesian Flow: -- G.P.M. -- P.S.I.
Water Temperature: 80 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ■ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
277	40	8 hours

9. WELL CONSTRUCTION
Depth Drilled: Feet Depth Cased: 475 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10.75	28.06	0.250	133.5	458.5
10.75	31.23	0.279	+1.5	133.5

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory cut perfs
Size of perforation: 1/8-in by 6-in, 2 rows per foot

From	Feet	To	Feet
373.5		453.5	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name: Rain 2 Day (Contractor)
Address: 24740 Industrial Park Court, Las Vegas, NV 891115 (Contractor)
Phone: 702 395-8849
Nevada contractor's license number as issued by the State Contractor's Board: 80355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): George Owen 2325
Signed: (By driller performing actual drilling on site or contractor)
Date: 5-25-16

(Rev. 04-16)
USE ADDITIONAL SHEETS IF NECESSARY