

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. # 71348

1. OWNER KINGS RIVER RANCH ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 129 Kings River Rd LAT. 41° 49' 12.9" NAD 83/WGS 84  
OROVADA, NEVADA 89425 LONG. 118° 14' 50.1"  
2. LOCATION SE 1/4 SE 1/4 Sec 34 T 46 N/S R 33 E Humboldt County  
PERMIT NO. 80391-20449 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Red House Stock Well

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	5	5
SANDY CLAY		5	45	40
BROWN CLAY		45	75	30
SAND AND GRAVEL		75	90	
SANDY CLAY		90	200	
SAND FINE	200	200	210	10
SAND + GRAVEL	}	220	230	20
PEA GRAVEL		230	250	20
BROWN CLAY	-	250	260	10
SAND + GRAVEL	260	260	310	50
HARD BROWN CLAY		310	315	5
SAND + GRAVEL	315	315	400	

8. WELL CONSTRUCTION  
Depth Drilled 400 Feet Depth Cased 398 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 Inches 0 Feet 200 Feet  
To 8 Inches 200 Feet 400 Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
8 0.250 0 400  
Perforations:  
Type perforation SAW SLOT  
Size perforation 1/8 x 2  
From 240 feet to 400 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 60  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 60 feet to 200 feet

Date started 10-20-15  
Date completed 3-5-16

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
Draw Down (Feet Below Static)	Time (Hours)		
<u>NO TEST</u>	<u>NAD 27</u>		
	<u>46.820353</u>		
	<u>118.246260</u>		

9. WATER LEVEL  
Static water level 172 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name KINGS RIVER RANCH Contractor  
Address 129 Kings River Road Contractor  
OROVADA, NEVADA  
Nevada contractor's license number \_\_\_\_\_ issued by the State Contractor's Board.  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1712  
Signed Mike McInch  
By driller performing actual drilling on site or contractor  
Date 3-10-16