STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125044
Permit No.
Basin No. 049

NOTICE OF INTENT NO. 74840
WELL NAME (if applicable):

1. OWNER/CLIENT NAME DUSTY SHIPP
MAILING ADDRESS 959 MONTROSE LN
ELKO NV, 89801

DETAILED ADDRESS AT WELL LOCATION 5759 OWYHEE AVE
BLK 7 LOT 1 3
Subdivision Name: MVR 9 County: ELKO

2. PLS LOCATION SW ¼ NE ¼ 31 Sec 34 N/S 55 E
PERMIT/WAIVER NO. 064-007-001
Issued by Water Resources Current Parcel No.

Latitude UTM E 599705 [X] NAD 27
Longitude UTM N 4515949 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [X] Rotary [ ] RVC
[X] Air [ ] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
ALLUVIUM			0	20'
SAND & GRAVEL			20'	80'
LIGHT GREEN CLAYS & GRAVELS			80'	120'
GRAVELS		XX	120'	152'

Date started: 2-Jun , 20 16
Date completed 2-Jun , 20 16

7. WATER QUALITIES
Static water level: 56' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 57 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
150'	50		1HR.
130'	45	NAD 27	.5HR
100'	25	40.790390	.5HR
80'	15	115.818249	.5HR
60'	6		.5HR

9. INSTRUCTION
Depth Drilled: 152' Feet Depth Cased: 152' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	152'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1.5	152'

ANNULAR MATERIALS
Sanitary Seal [X] Yes [ ] No

[X] Neat Cement	5'	to 25'	[ ] Pumped	[X] Poured
[ ] Cement Grout		to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to	[ ] Pumped	[ ] Poured
[X] Bentonite Chips	25'	to 55'	[ ] Pumped	[X] Poured
[X] Gravel Pack [> 0.2 in.]	55'	to 152'	[ ] Pumped	[X] Poured
[ ] Sand Pack [< 0.2 in.]		to	[ ] Pumped	[ ] Poured
[ ] Other, explain:		to	[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: PLASMA CUT
Size of perforation: 3/16" X 4" 6 ROWS

From 116'	Feet	To 152'	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC.
Contractor
Address P.O. BOX 850, ELKO, NV 89803
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 020582
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on site driller): 2329
Signed: By driller performing actual drilling on site or contractor
Date 6/2/2016

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY
pg. of pg.