STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125046
Permit No. 85347
Basin No. 101

NOTICE OF INTENT NO. 74174
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Aaron Williams
MAILING ADDRESS 7000 Casey Rd
Fallon NV 89406

DETAILED ADDRESS AT WELL LOCATION 7000 Curry Rd
Fallon NV 89406
Subdivision Name:
County Churchill

2. PLS LOCATION NW¼ NE ¼ 34 Sec 18 N/S 28 E
PERMIT/WAIVER NO. 85347 | 006-541-09
Issued by Water Resources *Current Parcel No*

Latitude
Longitude
UTM E 0342772 ☑ NAD 27
UTM N 4361030 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☑ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☑ Rotary ☐ RVC
☑ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Brown Sands & Clay			0	30	30
Black Sands & Clay			30	85	55
Gray Sands & Clay		X	85	96	11

Date started: 6-10-16
Date completed: 6-11-16, 20 , 20

7. WATER QUALITIES
Static water level: 10 Feet below land surface
Artesian Flow: G.P.M.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
40		1
	NAD 27	
	39.386322	
	118.825600	

9. WELL CONSTRUCTION
Depth Drilled: 96 Feet Depth Cased: 96 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	96	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	96

PERFORATIONS:
Type of perforation: Factory Cut
Size of perforation: 60 thousands 2" cut
From 89 Feet To 94 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☑ Sanitary Seal 0 to 50
☐ Neat Cement to ☑ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Welsco Corp *Contractor*
Address PO Box 888 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board*: 11752
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2539
Signed: *By driller performing actual drilling on site or contractor*
Date: 6-11-16

(Rev. 08-12)
(NSPO Rev 11-12)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627