STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125052
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74632
WELL NAME (*If applicable*):

1. OWNER/CLIENT NAME Jim Pasalich
MAILING ADDRESS 2301 Lucas Road
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 2301 Lucas Road
Fallon, NV 89406
Subdivision Name. *County.* Churchill

2. PLS LOCATION SE ¼ SE ¼ 13 Sec 19 N/S 27 E
PERMIT/WAIVER NO. *Issued by Water Resources* 007-251-28 *Current Parcel No.*

Latitude 39.5065 UTM E
Longitude -118.89483 UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # Unknown
☐ Reconditioin: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Brown Sand			0	15
Brown Clay			15	18
Brown Sand			18	21
Brown Clay			21	26
Brown Sand			26	42
Gray Silt			42	70
Gray Clay/Gravel			70	75
Gravel			75	90
Gray Silt/Sand			90	105
Sand/Gravel			105	110
Brown Gravel			110	118
Gray Sand			118	140
Gray Clay			140	152
Gray Sand			152	175
Gray Clay			175	177
Brown Sand		X	177	198

Date started: 24-May, 20 16
Date completed: 25-May, 20 16

7. WATER QUALITIES
Static water level: 38 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	NAD 27	
	39.506584	
	118.893840	

9. CONSTRUCTION
Depth Drilled: 198 Feet Depth Cased: 198 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	198	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	18
6	4.1	SDR21	18	198

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☒ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	198	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Saw Cut
Size of perforation: 1/8.

From	Feet	To	Feet
187	Feet	192	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89407 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board.* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1753
Signed *By driller performing actual drilling on site or contractor*
Date 6/1/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replacing unknown well log