STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1250058
Permit No. 62253
Basin No. 070

NOTICE OF INTENT NO. 73814
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Tebeau Piquet
MAILING ADDRESS 7605 Circle Bar Drive

DETAILED ADDRESS AT WELL LOCATION
7605 Circle Bar drive Winnemucca, NV - middle of pivot
Subdivision Name: County: Humboldt

2. PLS LOCATION NW ¼ SE ¼ 3 Sec 36 N/S 38 E
PERMIT/WAIVER NO. 62253 Issued by Water Resources
Current Parcel No.

Latitude 41° 1.402'N UTM E
Longitude 117° 40.953'W UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # 20983
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand and gravel			0	50
Gravel			50	60
Gravel and brown sand			60	100
Brown sandy clay			100	120
Gravel and brown sand			120	150
Gravel and brown clay			150	160
Gravel & sand			160	170
Gravel			170	200
Gravel w/clay			200	210
Gravel			210	230
Gravel w/clay			230	270
Black lava rock			270	300
Red lava rock			300	320
Black lava rock			320	350
Brown and red lava rock			350	390
Black lava rock			390	405

Date started: May 24th, 20 16
Date completed: June 6th, 20 16

7. WATER QUALITIES
Static water level: 22 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
2000	134'	4
	NAD 27	
	41.023464	
	117.681589	

9. WELL CONSTRUCTION
Depth Drilled: Feet Depth Cased: Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
36	Inches	0	Feet	50	Feet
22	Inches	50	Feet	405	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30"		0.375"	0	50
14"		0.375"	+2	400

ANNULAR MATERIALS
Sanitary Seal X Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
X Concrete Grout	50	to 0	X Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
X Gravel Pack [> 0.2 in.]	405	to 0	X Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Triple row mill slot
Size of perforation: 0.09

From 400	Feet	To 198.1	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Hydro Resources - West, Inc. (Contractor)
Address 4975 West Winnemucca Blvd. Winnemucca, NV 89445 (Contractor)
Phone (775) 623-5259
Nevada contractor's license number as issued by the State Contractors Board: 56797
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2529
Signed: Michelle Atwother (By driller performing actual drilling on site or contractor)
Date: 28-Jun-16

(Rev. 04-16)
USE ADDITIONAL SHEETS IF NECESSARY
pg. of pg.

Replacing well log 20983