STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125054
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 75867
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Charlie Mann
MAILING ADDRESS 2491 Roberson Lane
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 2491 Roberson Lane
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NE ¼ SE ¼ 18 Sec 19 N/S 28 E
PERMIT/WAIVER NO. 008-113-17
Issued by Water Resources *Current Parcel No.*

Latitude 39.50999 UTM E ☐ NAD 27
Longitude -118.87668 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen. Orig WL#
☒ Replacement: Original well log # Unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Brown Sand			0	15
Brown Clay			15	18
Brown Sand			18	30
Brown Clay			30	37
Brown Sand			37	44
Gray Clay			44	52
Gray Sand			52	65
Gray Silt			65	74
Gray Sand			74	86
Gray Clay			86	102
Gray Sand		X	102	138

Date started: 16-Jun , 20 16
Date completed: 17-Jun , 20 16

7. WATER QUALITIES
Static water level: 36 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	NAD 27	
	39.510074	
	118.875691	

9. INSTRUCTION
Depth Drilled. 138 Feet Depth Cased: 138 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	138	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6	4.1	SDR21	20	138

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	138	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.
From 127 Feet To 132 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge
Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265 Fallon, NV 89407
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1753
Signed. *By driller performing actual drilling on site or contractor*
Date: 6/21/2016

(Rev 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.

Replacing unknown well log