STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12512G
Permit No.
Basin No. 045

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74841
WELL NAME (If applicable):

1. OWNER/CLIENT NAME JIM GIBBONS
MAILING ADDRESS P.O.BOX 281286
LAMOILLE, NV 89828

DETAILED ADDRESS AT WELL LOCATION 2324 CLUBINE RD
LAMOILLE
Subdivision Name: RURAL County: ELKO

2. PLS LOCATION SW ¼ NE ¼ 16 Sec 33 N/S 58 E
PERMIT/WAIVER NO. 007-080-129
Issued by Water Resources Current Parcel No

Latitude UTM E 631773 [X] NAD 27
Longitude UTM N 4511703 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [X] Rotary [ ] RVC
[X] Air [ ] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
ALLUVIUM			0	5'
SAND & GRAVEL		XX	5'	160'

Date started 10-Jun , 20 16
Date completed 14-Jun , 20 16

9. CONSTRUCTION
Depth Drilled: 160' Feet Depth Cased: 160' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	0	Feet	20'	Feet
12 3/4	Inches	20'	Feet	160'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	22.38	.250	+1.5	160'

ANNULAR MATERIALS
Sanitary Seal [X] Yes [ ] No

[X] Neat Cement	5'	to 105'	[X] Pumped	[ ] Poured
[ ] Cement Grout		to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to	[ ] Pumped	[ ] Poured
[ ] Bentonite Chips		to	[ ] Pumped	[ ] Poured
[X] Gravel Pack [> 0.2 in.]	105'	to 160'	[ ] Pumped	[X] Poured
[ ] Sand Pack [< 0.2 in.]		to	[ ] Pumped	[ ] Poured
[ ] Other, explain:		to	[ ] Pumped	[ ] Poured

PERFORATIONS
Type of perforation: PLASMA CUT
Size of perforation: 3/16" X 4" 8 ROWS
From 120' Feet To 160' Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

7. WATER QUALITIES
Static water level: 43' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 54 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
160'	60	60'= 5.5 .5HR	1HR
140'	50'	NAD 27	.5HR
120'	25	40.747635	.5HR
100'	18	115-439177	.5HR
80'	26		.5HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC. (Contractor)
Address P.O. BOX 850, ELKO, NV 89803 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 020582
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2329
Signed: (Driller performing actual drilling on site or contractor)
Date: 6/14/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.