STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125132
Permit No.
Basin 069

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 75690

1. OWNER Ralph Whitworth
MAILING ADDRESS 3525 DelMar Heights#820 SanDiego CA

ADDRESS AT WELL LOCATION 240 East Street
Paradise Valley
Subdivision Name: N/A County: Humboldt

2. LOCATION NE¼SW¼ Sec25T42N/ R39E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 4239-25-326-006 (Parcel. No.)

Latitude 41°29.423' UTM E ☐ NAD 27
Longitude 117°32.024' N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	2	2
Clay		2	15	13
Cobles		15	80	65
Sand fine	X	80	95	15
Clay		95	98	3
Sand fine	X	98	115	17
Clay		115	117	2
Course sand/gravel	X	117	180	63

Date started: June 17, 20 16
Date completed: June 20, 20 16

RECEIVED 2016 JUL -5 AM 10:51 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18	180

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32x4
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 105 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 105 to 180 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 48 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: 55 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-25		4
	NAD 27	
	41.490487	
	117.532771	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed (By driller performing actual drilling on site or contractor)
Date July 1, 2016

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

Plugging unknown well log