

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 125177  
Permit No. 85904T  
Basin No. 230

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 39004  
WELL NAME (if applicable): R2

1. OWNER/CLIENT NAME Rockview Dairies  
MAILING ADDRESS PO Box 70  
Amargosa Valley, Nv. 89020

DETAILED ADDRESS AT WELL LOCATION 870 E. Mecca rd  
Amargosa Valley, Nv.  
Subdivision Name: \_\_\_\_\_ County: Nye

2. PLS LOCATION NE 1/4 SE 1/4 4 Sec 17 No 49 E  
PERMIT/WAIVER NO. 85904T 019-381-04  
W-2116 Issued by Water Resources Current Parcel No.

Latitude N 36.501363° UTM E  NAD 27  
Longitude W 116.449763° UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Mining / Dewater  
 Test / Other  
 Irrigation  Monitor  
 Com / Ind  Stock  
 Mun / QM  Rec  Other

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Course sand, pebbles			0	10	10
Sand, gravel			10	40	30
Brown quartz sand			40	80	40
gravel			80	90	10
yellow quartz sand			90	140	50
Sand, gravel		X	140	160	20
course sand			160	210	50
Sand, clay			210	230	20
course sand			230	240	10
silt, sand			240	270	30
Sand, gravel			270	280	10
Brown silt, sand, clay			280	330	50
course sand			330	360	30
silt, clay			360	420	60
Sand			420	430	10
Sand, clay			430	450	20
silt, sand			450	490	40
Sand, clay			490	540	50
clay			540	550	10
cemented gravels			550	580	30
Basalt Andesite			580	610	
cemented gravel			610	630	
Cemented gravel, clay			630	680	
Basalt			680	710	
Green clay			710	720	
Basalt			720	756	

9. WELL CONSTRUCTION  
Depth Drilled: 756 Feet Depth Cased: 756 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>27</u> Inches	<u>0</u> Feet
	<u>756</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16"</u>	<u>62.3</u>	<u>.375</u>	<u>+ 2</u>	<u>756</u>

PERFORATIONS:  
Type of perforation: Factory milled  
Size of perforation: 3/16 x 2 1/2  
From 242 Feet To 756 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS

Sanitary Seal \_\_\_\_\_ to \_\_\_\_\_  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  
 Concrete Grout 0 to 52  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  
 15 %  20 %  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] 52 to 756  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_

Date started: Feb. 20, 20 16  
Date completed: May 15, 20 16

7. WATER QUALITIES  
Static water level: 137.0 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: 85.5 ° Fahrenheit  
Water Quality: Good

8. WELL TEST DATA

Test Method:	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<u>Air lift</u>			<input checked="" type="checkbox"/>	<u>800</u>		<u>12 hours</u>
<u>pump test</u>				<u>3200</u>	<u>156'</u>	<u>73 hours</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name webber Drilling Contractor  
Address PO Box 40 Overton, Nv. 89040 Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 0025887  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2238  
Signed: Bryan Anzalone  
By driller performing actual drilling on site or contractor  
Date: May 18 2016

(Rev. 08-12)  
(NSPO Rev 11-12)

USE ADDITIONAL SHEETS IF NECESSARY

36.5014093 NAD  
-116.448882 27