

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT**

OFFICE USE ONLY
Log No. 125235
Permit No. _____
Basin No. 089

**PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 74963
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME WILL FLETCHER
MAILING ADDRESS 250 ROXBURY WAY
CARSON CITY, NV 89703

DETAILED ADDRESS AT WELL LOCATION 835 BRENDA WAY
WASHOE VALLEY, NV 89704
Subdivision Name: _____ County: Washoe

2. PLS LOCATION NE 1/4 NW 1/4 30 Sec 17 N/S 20 E
PERMIT/WAIVER NO. 050-254-07
Issued by Water Resources Current Parcel No.

Latitude 39.3163.23°N UTM E NAD 27
Longitude 119.782012°W UTM N NAD 83WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To |
|------------------------|------------|--------------|------|-----|
| OVER BURDEN | | | 0 | 5 |
| DG SANDS AND GRAVELS | | | 5 | 145 |
| HARD GRANITE | | X | 145 | 200 |
| VERY HARD BLUE GRANITE | | | 200 | 340 |
| DG GRANITE RUSTY | | X | 340 | 380 |
| FRACTURED GRANITE | | XXX | 380 | 420 |

9. WELL CONSTRUCTION

Depth Drilled: 420 Feet Depth Cased: 420 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---------------|------|-----|
| 11 1/4 Inches | 0 | 120 |
| 9 7/8 Inches | 120 | 200 |
| 6 1/8 Inches | 200 | 420 |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 13.03 | .188 | 2 | 200 |
| 5 1/4 | 10.96 | .188 | 180 | 420 |

Date started: 16-May, 20 16
Date completed: 23-May, 20 16

ANNULAR MATERIALS

Sanitary Seal Yes No

Neat Cement _____ to _____ Pumped Poured

Cement Grout 0 to 65 Pumped Poured

Concrete Grout _____ to _____ Pumped Poured

Bentonite Chips _____ to _____ Pumped Poured

Gravel Pack [> 0.2 in.] 65 to 200 Pumped Poured

Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured

Other, explain: _____ to _____ Pumped Poured

7. WATER QUALITIES

Static water level: 95' Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 55° ° Fahrenheit
Water Quality: GOOD

PERFORATIONS:

Type of perforation: FACTORY MILL SLOT

Size of perforation: 3 X 3/32

From 180 Feet To 200 Feet
From 380 Feet To 420 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

8. WELL TEST DATA

Test Method: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|-----------|-------------------------------|-----------------------|
| <u>20</u> | <u>160</u> | <u>3 HOURS</u> |
| | <u>NAD 27</u> | |
| | <u>39.316413</u> | |
| | <u>119.780994</u> | |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor

Address 20 KIT KAT DRIVE 20 KIT KAT DRIVE CARSON CITY NV 89706
Contractor

Phone _____

Nevada contractor's license number as issued by the State Contractors Board: 0055548

Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): _____ 1905

Signed: [Signature]
by driller performing actual drilling on the well/contractor

Date: 6/6/2016