STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125237
Permit No.
Basin No. 099

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73211
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Jeffrey Mehoves
MAILING ADDRESS 1365 Greenbrae Dr
Sparks, NV 89431

DETAILED ADDRESS AT WELL LOCATION 22075 N. Red Rock Road
Reno, NV 89508
Subdivision Name Rancho Haven County: Washoe

2. PLS LOCATION ~~SW~~ ¼ NW ¼ NW ¼ 4 Sec. 23 N/S 18 E
PERMIT/WAIVER NO (Issued by Water Resources) 078-291-26 (Current Parcel No.)

Latitude 39.89133 UTM E ☐ NAD 27
Longitude -119.97783 UTM N ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
☐ Air ■ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand			0	8
Brown Clay			8	12
Tan & Yellow Clay			12	20
Yellow Clay			20	50
Brown Sand			50	60
Brown Sand & Brown Clay			60	120
Brown Clay			120	160
Sand & Tan Clay			160	220
Sand, Gravel, Brown Clay			220	240
Grey Clay			240	260
T.D. 278'				

Date started: 24-May, 20 16
Date completed: 6-Jun, 20 16

7. WATER QUALITIES
Static water level: 160 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	10		3 Hours
		NAD 27	
		39.891424	
		119.976797	

9. INSTRUCTION
Depth Drilled: 278 Feet Depth Cased: 278 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	278	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	0.188	+2	278

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

■ Neat Cement	0 to 50	■ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ Bentonite Chips	to	☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in.]	50 to 278	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation: Factory Perforated
Size of perforation: 3/32 x 3

From	Feet	To	Feet
238	Feet	258	Feet
120	Feet	140	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address P.O. Box 60130 Reno, Nevada 89506 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board* 35387C
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)* 2362
Signed: Larry Welch (By driller performing actual drilling on site or contractor)
Date 6/7/2016

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY