STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125241
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74626
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Steve Noyes
MAILING ADDRESS 2646 Rice Rd.
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 2646 Rice Rd.
Fallon, NV 89406
Subdivision Name. County. Churchill

2. PLS LOCATION SE ¼ SW ¼ 23 Sec 19 N/S 28 E
PERMIT/WAIVER NO. 010-471-20
Issued by Water Resources Current Parcel No

Latitude 39.49246 UTM E ☐ NAD 27
Longitude -118.81326 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # Unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	30
Brown Clay			30	35
Gray/Brown Clay			35	45
Gray Clay			45	55
Black Sand/ Gray Clay			55	60
Gray Clay			60	70
Brown gravel/Gray Clay			70	75
Brown Gravel		X	75	105

Date started: 29-Apr , 20 16
Date completed: 10-May , 20 16

9. INSTRUCTION
Depth Drilled: 105 Feet Depth Cased: 105 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	105	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	25
6	4.1	SDR21	25	105

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	105	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.

From	Feet	To	Feet
101	Feet	104	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 17 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	NAD 27	
	39.492543	
	118.812273	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265 Fallon, NV 89407
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1753
Signed [signature]
By driller performing actual drilling on site or contractor
Date. 6/1/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replacing unknown well log