

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125320
Permit No. _____
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25854
22033
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Mayer Baylog
MAILING ADDRESS BUS McLean Rd
Fallon NV 89406

DETAILED ADDRESS AT WELL LOCATION 845 McLean Rd
Fallon NV 89406
Subdivision Name: _____ County: Church, 11

2. PLS LOCATION NW 1/4 SE 1/4 31 Sec 19 N/S 29 E
PERMIT/WAIVER NO. 007-715-27
Issued by Water Resources Current Parcel No.

Latitude _____ UTM E 0347690 NAD 27
Longitude _____ UTM N 4361890 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # None
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
<u>Brown Sands & clay</u>			<u>0</u>	<u>35</u>	<u>35</u>
<u>Black sand & clay</u>			<u>35</u>	<u>40</u>	<u>5</u>
<u>Case sand & clay</u>			<u>90</u>	<u>110</u>	<u>20</u>
<u>Orange clay fine sand</u>			<u>110</u>	<u>125</u>	<u>15</u>
<u>Brown Sand & clay</u>		<u>X</u>	<u>125</u>	<u>136</u>	<u>11</u>

9. WELL CONSTRUCTION

Depth Drilled: 136 Feet Depth Cased: 136 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10 3/4</u>	<u>0</u>	<u>103</u>
<u>6 7/8</u>	<u>103</u>	<u>136</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.9</u>	<u>.188</u>	<u>0</u>	<u>136</u>

PERFORATIONS:

Type of perforation: Taylor cut
Size of perforation: 60 thousand 2" cut
From 129 Feet To 134 Feet

ANNULAR MATERIALS

Sanitary Seal _____ to _____
 Neat Cement 0 to 103 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 Bentonite Chips _____ to _____ Pumped Poured
 Bentonite Grout _____ to _____ Pumped Poured
 15 % 20 % Other, explain: _____
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] _____ to _____ Pumped Poured
 Other, explain: _____ to _____ Pumped Poured

Date started: 6-7-16, 20
Date completed: 6-8-16, 20

7. WATER QUALITIES
Static water level: 23' Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>NAD 27</u>	<u>1</u>
		<u>39.467006</u>	
		<u>118.770541</u>	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Webco Corp Contractor
Address 1600 888 Contractor

Nevada contractor's license number as issued by the State Contractor's Board. 11752
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2539
Signed: _____
Date: 6-8-16
By driller performing actual drilling on site or contractor