

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 123341  
Permit No. \_\_\_\_\_  
Basin No. 049

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37978  
WELL NAME (if applicable): MW-9

1. OWNER/CLIENT NAME Bob Hardy / Hardy Enterprise Inc.  
MAILING ADDRESS PO Box 248  
Bountiful UT 84011

DETAILED ADDRESS AT WELL LOCATION 1790 Idaho St  
Elko NV  
Subdivision Name: \_\_\_\_\_ County: Elko

2. PLS LOCATION SE ¼ SW ¼ 11 Sec 34 NS 55 E  
PERMIT/WAIVER NO. M/O - 2063 001-590-004  
Issued by Water Resources Current Parcel No.

Latitude 40.842209 UTM E  NAD 27  
Longitude 115.751048 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  
 Mining / Dewater  
 Test / Other  
 Irrigation  
 Com / Ind  
 Mun / QM  
 Monitor  
 Stock  
 Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
TYPE II Base			0	1
Silt damp dark brown stiff silty fines with no plasticity			1	14
Silt damp yellow brn stiff, sand			14	20
Clay moist YB stiff clay			20	24
Sandy gravel damp gray, sand			24	28
Silt damp dark brn stiff			28	32
Sandy gravel moist gray, cobbles sand			32	48
Silt sanp, dark brn, silty fines			48	54
Clay damp YB very stiff clay			54	66
Silt damp YB silty fines, sand			66	80
Sandy gravel, wet, gray sand			80	92
Silt wet YB stiff sand, gravel			92	97
Clay w sand & gravel wet, YB stiff clay snad gravel				106
Clay damp YB hard clay			106	107

9. INSTRUCTION  
Depth Drilled: 107 Feet Depth Cased: 107 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
7.58 Inches 0 Feet 107 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.68</u>	<u>0.154</u>	<u>0</u>	<u>107</u>

ANNULAR MATERIALS  
Sanitary Seal  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0.5 to 20  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips 20 to 24  Pumped  Poured  
 Gravel Pack [ > 0.2 in. ] to \_\_\_\_\_  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] 24 to 107  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Bentonite Chips - Poured from 135 to 76' 8" Borehole

PERFORATIONS:  
Type of perforation: Factory  
Size of perforation: 0.02  
From 27 Feet To 107 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Date started: 2-Jun , 20 16  
Date completed: 4-Jun , 20 16

7. WATER QUALITIES  
Static water level 80 Feet below land surface  
Artesian Flow: NA G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: NA ° Fahrenheit  
Water Quality: NA

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name National EWP Contractor  
Address 4221 West Oquendo RD, Las Vegas, NV 89118 Contractor

8. WELL TEST DATA		
Test Method:	G.P.M.	Recorded Time (Hours)
<input checked="" type="checkbox"/> Baker <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	<u>NAD 27</u>	
	<u>40.842288</u>	
	<u>115-750147</u>	

Nevada contractor's license number as issued by the State Contractor's Board 00296066-75355  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512  
Signed: Bob Hardy  
By driller performing actual drilling on site or contractor  
Date 7/21/2016