STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125368
Permit No.
Basin No. 103

NOTICE OF INTENT NO. 74424
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Clayton Homes
MAILING ADDRESS 10020 Hwy 50 CC NV 89706

DETAILED ADDRESS AT WELL LOCATION 330 San Clemente Ave
Subdivision Name:
County: Storey

2. PLS LOCATION NW ¼ NE ¼ 30 Sec 17 N/S 22 E
PERMIT/WAIVER NO. 03-283-19
Issued by Water Resources *Current Parcel No*

Latitude 39.313440 UTM E
Longitude 119.554059 UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ ~~Replacement: Original well log #~~
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dirt			0	19	19
Brown Clay			19	24	5
Brown & Black Chip rock			24	96	70
Brown Clay			96	108	12
Chip Rock			108	179	71
Multi Colored Chip rock			179	246	67
Clay			246	261	15
Multi Color chip Rock			261	320	59
Some Small Gravel					

Date started: 7-11, 20 16
Date completed: 7-15, 20 16

7. WATER QUALITIES
Static water level: 165 Feet below land surface
Artesian Flow: No G.P.M. 20 P.S.I.
Water Temperature: 57 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		3
	NAD 27	
	39.313526	
	119.553051	

9. WELL CONSTRUCTION
Depth Drilled: 320 Feet Depth Cased: 320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	75	Feet
9 7/8	Inches	75	Feet	320	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	20
6 5/8		SDR 21	20	320

PERFORATIONS:
Type of perforation: Factory Cut
Size of perforation: 3/32
From 320 Feet To 280 Feet
From 260 Feet To 240 Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0	to 56		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0	to 56	☐ Pumped	☒ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☐ Gravel Pack [> 0.2 in.]	56	to 320	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC. *Contractor*
Address P.O. Box 1255 Carson City, NV 89702 *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2514

Signed: Bl Gallina *By driller performing actual drilling on site or contractor*
Date: 7-15-16

(Rev. 08-12)
(NSPO Rev 11-12)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627