CARSON CITY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125409
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirely in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65293

1. OWNER CARL EDAUGH
MAILING ADDRESS 28114 Bobwhite Circle #27 ARGUS CALIFORNIA 91350
ADDRESS AT WELL LOCATION 375 EAST WARD NOT PRIVE, ELY, NEV
Subdivision Name. County: White Pine

2. LOCATION NW¼ NW ¼ Sec 24 T 14 N R 63 E
PERMIT/WAIVER No. 012-110-19 (Issued by Water Resources) Parcel No.
Latitude 39°04'1012" Longitude 114°51:02.96"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel + Boulders		0	85	
Sandy + Clay		8	140	
Sandy + Water		140	160	
Reddish Clay		160	180	
White Sand + Water		180	210	
Gravel + Water		210	250	
Sand		250	310	

JCNR/DWR/SNBC
RECEIVED
SEP 19 2016

Date started: AUG 19, 20 15
Date completed: AUG 31, 20 16

7. Water Level
Static water level: 82 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	50	Feet
9⅞	Inches	50	Feet	310	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝		.188	+2	70
6⅝	Sch 40	Pr ≤ 46	26	310

Perforations:
Type of perforation FACTORY
Size of perforation ⅛"

From 100	feet to	120	feet
From 160	feet to	180	feet
From 220	feet to	240	feet
From 290	feet to	300	feet
From	feet to		feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	0 to 60		☐ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) VERNON H DIMICK
Address (Contractor) 8605 W COUGAR AVE, L.V. NV 89148
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V.H. Dimick (By driller performing actual drilling on-site or contractor)
Date 9-19-2016

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) NAD 27: 39.069536, -114.849974

(O) 627