STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125487
Permit No.
Basin No. 101

NOTICE OF INTENT NO. 74947
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Enrique Soriano
MAILING ADDRESS 110 Lilly Lane
Fernley, NV 89408

DETAILED ADDRESS AT WELL LOCATION 500 California Street
Hazen, NV
Subdivision Name: *County:* Churchill

2. PLS LOCATION NW ¼ ~~SW~~ ¼ 27 Sec 20 N/S 26 E
PERMIT/WAIVER NO. SE *Issued by Water Resources* 010-271-05 *Current Parcel No.*

Latitude 39.5661 UTM E ☐ NAD 27
Longitude -119.0488 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen. Orig WL#
☒ Replacement: Original well log # Unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Clay			0	10
Gravel			10	36
Rock/Gravel			36	47
Black Clay/Rock			47	102
Black Rock		X	102	115

9. CONSTRUCTION
Depth Drilled: 115 Feet Depth Cased: 115 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	115	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6	4.1	SDR21	20	115

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	115	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut.
Size of perforation: 1/8.

From	Feet	To	Feet
From 104	Feet	To 109	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

Date started: 29-Jun, 20 16
Date completed: 30-Jun, 20 16

7. WATER QUALITIES
Static water level: 12 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
	NAD 27	
	39.566186	
	119.047805	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89407 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1753
Signed. Wayne Parsons *By driller performing actual drilling on site or contractor*
Date. 7/6/2016

(Rev. 12-13)

USE ADDITIONAL SHEETS IF NECESSARY

pg. of pg.

Replacing unknown well log