STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125510
Permit No. 85706
Basin No. 083

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73216
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME NV-AG / Don Evans
MAILING ADDRESS 5555 Tancho Dr.#201
Madison,WI 53718

DETAILED ADDRESS AT WELL LOCATION 31850 Cantlon Dr.
Wadsworth,NV
Subdivision Name *County:* Washoe

2. PLS LOCATION NE ¼ NE ¼ 18 Sec 20 N/S 24 E
PERMIT/WAIVER NO 85706 *Issued by Water Resources* 084-282-16 *Current Parcel No*

Latitude 39.607178 UTM E ☒ NAD 27
Longitude 119.321465 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☒ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Orginal bore to 98 feet ,due to migr				
rating mud in to domestic well. Drill				
ing was stop and neat cement pum				
ped to suface to abandon.	X	X	0	98
Sand			0	20
Multi colored rock	X		20	200
Multi Colored rock and gray clay		X	200	260
Black Volcanic rock			260	380
Multi colored rock and red clay		X	380	460
Multi colored and gray clay			460	480
Gray clay and sand			480	540
Gray clay			540	560
Black and white granite			560	580
Multi colored rock and brown clay			580	620
Multi colored rock and gray clay			620	698
T.D. 698				

Date started: 17-Jun , 20 16
Date completed: 13-Jul , 20 16

7. *WATER QUALITIES*
Static water level: 50 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 68 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air lift	75	140	6 hrs
	100	240	2hrs
	125	460	3hrs

9. *WELL CONSTRUCTION*
Depth Drilled: 698 Feet Depth Cased: 698 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-5.8	Inches	0	Feet	105	Feet
8-1/2	Inches	105	Feet	698	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	+3	698

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	100	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	698	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory Sawed
Size of perforation: 3/32 x 3

From	140	Feet	To	200	Feet
From	400	Feet	To	460	Feet
From		Feet	To		Feet
From		Feet	To		Feet
From		Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service,LLC. *Contractor*
Address P.O. Box 60130 Reno,Nevada 89506 *Contractor*
Phone 775-677-4433
Nevada contractor's license number as issued by the *State Contractor's Board:* 35387C
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2362
Signed: *Driller performing actual drilling on site of contractor*
Date: 7/18/2016

(Rev. 04-16) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1