STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125511
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37345

1. OWNER JOSE & LETICIA TOPETE
MAILING ADDRESS 945 SAINT MORTZ DR
HENDERSON NV 89012

ADDRESS AT WELL LOCATION 9950 RANCHO DESTINO
Subdivision Name: CALVADA VLY U14 County: NYE

2. LOCATION SE ¼ NW ¼ Sec 28 T 22S N/S R 61 E
PERMIT/WAIVER No. 177-28-203-001
Issued by Water Resources Parcel No.

Latitude N36°00'34.3" Longitude W115°09'52.8"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & CLAY		0	30	-30
SAND, CLAY & GRAVEL		30	90	-60
VARIOUS Quartz, Limestone, Sandstones & Slate, Fractured w/Clay	WB	90	400	-310

DCNR/DWR/SNBO RECEIVED JUL 28 2016

Date started: 18-Jul, 20 16
Date completed: 25-Jul, 20 16

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12-1/4	Inches	0	Feet	51	Feet
7-7/8	Inches	51	Feet	400	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	+1.5	-51
4.5	2.794	.248	0	400

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 280 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 51 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 4 to 400 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 108 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2513
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/26/2016

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

NAD 27 36.0095536 -115.163838