STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125524
Permit No.
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74820
WELL NAME (*If applicable*): HD-16-8E

1. OWNER/CLIENT NAME Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480,
Round Mountain, NV. 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Mine,
Round Mountain, NV.
Subdivision Name. *County:* Nye

2. PLS LOCATION SE ¼ NE ¼ 30 Sec 10 (N)S 44 E
PERMIT/WAIVER NO. M/O-2071
Issued by Water Resources *Current Parcel No*

Latitude UTM E 493254 [X] NAD 27
Longitude UTM N 4283186 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Monitor
[X] Mining / Dewater [ ] Com / Ind [ ] Stock
[ ] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [X] Rotary [ ] RVC
[ ] Air [ ] Mud [ ] Sonic
[ ] Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Grey rock			0	400
Grey granite			400	650
Grey rock with some black rock			650	720
6" X 1-1/2" Well seal installed				

Date started: 30-Jul , 20 16
Date completed: 31-Jul , 20 16

9. CONSTRUCTION
Depth Drilled: 720 Feet Depth Cased: 720 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9.875	Inches	0	Feet	20	Feet
5.5	Inches	20	Feet	720	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	18.97	.280	0	20
1.5	0.69	.200	+.5	720

ANNULAR MATERIALS
Sanitary Seal X Yes [ ] No

[X] Neat Cement	0 to 20	[X] Pumped	[ ] Poured
[ ] Cement Grout	to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout	to	[ ] Pumped	[ ] Poured
[ ] Bentonite Chips	to	[ ] Pumped	[ ] Poured
[ ] Gravel Pack [> 0.2 in.]	to	[ ] Pumped	[ ] Poured
[ ] Sand Pack [< 0.2 in.]	to	[ ] Pumped	[ ] Poured
[ ] Other, explain:	to	[ ] Pumped	[ ] Poured

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: 0.020
From 60 Feet To 720 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: 9 G.P.M. N/A P.S.I.
Water Temperature: 132 ° Fahrenheit
Water Quality: Fair

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
N/A	N/A	
	NAD 27	
	38.699138	
	117.077576	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear
Contractor
Address 2745 California Ave., SLC., UT. 84104
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board* 0021976
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller).* 2486
Signed: [signature]
By driller performing actual drilling on site or contractor
Date. 4-Aug-16

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1