STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125526
Permit No.
Basin No. 137B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74821
WELL NAME (if applicable): HD-16-8G

1. OWNER/CLIENT NAME Round Mountain Gold Corp.
MAILING ADDRESS P.O. Box 480, Round Mountain, NV. 89045

DETAILED ADDRESS AT WELL LOCATION Round Mountain Mine, Round Mountain, NV.
Subdivision Name: County: Nye

2. PLS LOCATION SW ¼ NE ¼ 30 Sec 10 N/S 44 E
PERMIT/WAIVER NO. M/O-2071 (Issued by Water Resources) Current Parcel No.

Latitude UTM E 493239 ☒ NAD 27
Longitude UTM N 4283181 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☒ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Light grey rock w/clay			0	200
Dark grey rock			200	400
Light grey rock w/clay			400	420
Grey rock			420	740
6" X 1-1/2" Well seal installed				

Date started: 23-Jul , 20 16
Date completed: 25-Jul , 20 16

9. CONSTRUCTION
Depth Drilled: 740 Feet Depth Cased: 740 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9.875	Inches	0	Feet	20	Feet
5.5	Inches	20	Feet	740	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	18.97	.280	0	20
1.5	0.69	.200	+.5	740

ANNULAR MATERIALS
Sanitary Seal X Yes ☐ No

☒ Neat Cement	0	to 20	☒ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 In.]		to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: 0.02

From 60	Feet	To 740	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: N/A ° Fahrenheit
Water Quality: N/A

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
N/A	N/A	
	NAD 27	
	38.699093	
	117.077749	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 2745 California Ave., SLC., UT. 84104 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2486
Signed: (By driller performing actual drilling on site or contractor)
Date. 27-Jul-16

(Rev 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. 1 of pg. 1