STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125540
Permit No.
Basin No. 103

NOTICE OF INTENT NO. 74974
WELL NAME (If applicable):

1. OWNER/CLIENT NAME TERRY BUNKOWSKI
MAILING ADDRESS 26 BILL EITEL ROAD
DAYTON, NV 89403

DETAILED ADDRESS AT WELL LOCATION 26 BILL EITEL ROAD
DAYTON, NV 89403
Subdivision Name:
County: Lyon

2. PLS LOCATION ~~NW~~ ¼ ~~NW~~ ¼ 12 Sec 16 N/S ~~22~~ 21 E
PERMIT/WAIVER NO. SE NE (Issued by Water Resources) 016-341-11 (Current Parcel No.)

Latitude ~~[illegible]~~ UTM E 39.267193 ☐ NAD 27
Longitude ~~[illegible]~~ UTM N 119.569138 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
OVER BURDEN			0	4
COURSE GRAVELS			4	56
LARGE GRAVELS			56	145
BROWN CLAY			145	162
COURSE DG SANDS, GRAVELS			162	195
LARGE GRAVELS		XXX	195	240

Date started: 19-Jul, 20 16
Date completed: 21-Jul, 20 16

7. WATER QUALITIES
Static water level: 46' Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 49° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
65	125	3 HOURS
	NAD 27	
	39.267279	
	119.568131	

9. WELL CONSTRUCTION
Depth Drilled: 240 Feet Depth Cased: 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11 5/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6 5/8 SDR	4.26	.216	20	240
21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	100	to	240	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	240	☐ Pumped	☐ X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3 X 3/32
From 180 Feet To 240 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Phone
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2543

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 7/26/2016

(Rev. 04-16)

USE ADDITIONAL SHEETS IF NECESSARY

pg. of pg.