STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125541
Permit No.
Basin No. 103

NOTICE OF INTENT NO. 74969
WELL NAME (If applicable):

1. OWNER/CLIENT NAME JEFF KRECK
MAILING ADDRESS 5510 CAMUS RD
CARSON CITY, NV 89706

DETAILED ADDRESS AT WELL LOCATION 5510 CAMUS ROAD
CARSON CITY, NV 89706
Subdivision Name.
County: Carson City

2. PLS LOCATION NW ¼ SE ¼ 23 Sec 15 N/S 20 E
PERMIT/WAIVER NO. 010-105-12
Issued by Water Resources — Current Parcel No

Latitude 39.146444*N UTM E
Longitude 119.70515*W UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# N/A
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OLD 6 5/8 WELL			0	90
BROWN CLAY			90	110
DG SANDS			110	165
SILTY SANDS			165	190
COURSE FRACTURED GRAVEL		XXX	190	240

Date started 12-Jul, 20 16
Date completed 15-Jul, 20 16

9. WELL CONSTRUCTION
Depth Drilled: 150 Feet 150 Depth Cased: 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	90	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	4.26	.216	80	240

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout	N/A	to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	N/A	to	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: FACTORY SLOT
Size of perforation: 0.032

From	Feet	To	Feet
200	Feet	240	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 75 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 51* ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
25	60	3 HOURS
	NAD 27	
	39.146534	
	119.704139	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT SDRIVE CARSON CITY, NV 89706
Contractor
Phone
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1906
Signed [signature]
By driller performing actual drilling on site or contractor
Date: 7/29/2016

(Rev. 04-16)
USE ADDITIONAL SHEETS IF NECESSARY
pg. of pg.

Deepening unknown well log