STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125557
Permit No.
Basin No. 108

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74975
WELL NAME (if applicable):

1. OWNER/CLIENT NAME MONTY TAVARES
MAILING ADDRESS 2730 LAKESHORE BLVD
UPPERLAKE CA, 95485

DETAILED ADDRESS AT WELL LOCATION 17 LYNN LEE LANE
YERINGTON, NV 89447
Subdivision Name: County: Lyon

2. PLS LOCATION ¼ SE ¼ NW 26 Sec 14 N/S 26 E
PERMIT/WAIVER NO. 014-351-55
Issued by Water Resources Current Parcel No.

Latitude 39.050344*N UTM E ☐ NAD 27
Longitude 119.044593*W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
OVER BURDEN			0	3
BROWN COURSE SANDS			3	20
BROWN SANDY CLAYS			20	100
BROWN CLAY			100	140
COURSE SANDS DG SANDS			140	180
COURSE GRAVELS AND OBSIDIAN SANDS		XXX	180	200

Date started: 1-Aug , 20 16
Date completed: 3-Aug , 20 16

7. WATER QUALITIES
Static water level: 80 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 52° ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20	50	3 HOURS
	NAD 27	
	39.050425	
	119.043606	

9. WELL CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11 1/4	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	2	20
6 5/8	4.26	.216	20	200
SDR 21				

ANNULAR MATERIALS
Sanitary Seal X ☐ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	50	☐ Pumped	☐ X Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	200	☐ Pumped	☐ X Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 3 X 3/32

From	Feet	To	Feet
160	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE CARSON CITY, NV 89706
Contractor
Phone
Nevada contractor's license number as issued by the State Contractor's Board: 0055548
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2010
Signed: [signature]
By driller performing actual drilling on site or contractor
Date. 8/15/2016

(Rev. 04-16) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.