

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 125584  
Permit No. \_\_\_\_\_  
Basin No. \_\_\_\_\_

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35777  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Billick Family Trust DETAILED ADDRESS AT WELL LOCATION Penson rd  
MAILING ADDRESS HC 72 Box 00513 MP 1 Dyer, Nv. 89010  
Subdivision Name: \_\_\_\_\_ County: Esmeralda

2. PLS LOCATION NW 1/4 22 Sec 4 N 36 E Latitude 37° 34.896' UTM E  NAD 27  
PERMIT/WAIVER NO. 007-631-01 Longitude 117° 58.285' UTM N  NAD 83/WGS 84  
Issued by Water Resources Current Parcel No

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL#  
 Replacement: Original well log # 38374  
 Recondition: Original well log #  
4. PROPOSED USE  
 Domestic  Irrigation  Monitor  Auger  Rotary  RVC  
 Mining / Dewater  Com / Ind  Stock  Air  Mud  Sonic  
 Test / Other  Mun / QM  Rec  Other

| LITHOLOGIC LOG       |            |              |      |     |            |
|----------------------|------------|--------------|------|-----|------------|
| Material Encountered | Lost Circ. | Water Strata | From | To  | Thick-ness |
| silt, clay           |            |              | 0    | 40  | 40         |
| sand, gravel         |            |              | 40   | 120 | 80         |
| clay                 |            |              | 120  | 150 | 30         |
| sand, gravel         |            |              | 150  | 270 | 120        |
| sandy clay           |            |              | 270  | 290 | 20         |
| sand, fine gravel    |            |              | 290  | 360 | 70         |
| clay                 |            |              | 360  | 390 | 30         |
| sand, gravel         |            |              | 390  | 420 | 30         |

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other  
6. WELL CONSTRUCTION  
Depth Drilled: 420 Feet Depth Cased: 420 Feet  
HOLE DIAMETER (BIT SIZE)  
From 11 Inches To 0 Feet 420 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

| CASING SCHEDULE    |                     |                         |             |           |
|--------------------|---------------------|-------------------------|-------------|-----------|
| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
| 6                  | 24                  | .280                    | 0           | 20        |
| 6                  |                     | SDR 17                  | 20          | 420       |

PERFORATIONS:  
Type of perforation: Screen  
Size of perforation: .032  
From ~~0~~ Feet To ~~420~~ Feet  
From 220 Feet To 420 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS  
 Sanitary Seal \_\_\_\_\_ to \_\_\_\_\_  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 58  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 15%  20%  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] 58 to 420  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: Oct. 22, 20 15  
Date completed: Oct 24, 20 15

7. WATER QUALITIES  
Static water level: 142.3 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: Good

| WELL TEST DATA |                          |                               |                                     |
|----------------|--------------------------|-------------------------------|-------------------------------------|
| Test Method:   | Bailer                   | Pump                          | Air Lift                            |
| Air lift       | <input type="checkbox"/> | <input type="checkbox"/>      | <input checked="" type="checkbox"/> |
|                | G.P.M.                   | Draw Down (Feet Below Static) | Recorded Time (Hours)               |
|                | <u>100</u>               |                               | <u>6 hrs</u>                        |

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Nv. webber Drilling Contractor  
Address PO Box 40 Overton, Nv. 89040 Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 0025887  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2238  
Signed: Bryan Anzalone  
Date: Dec 30, 2015  
Driller performing actual drilling on site or contractor