

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 125586  
Permit No. \_\_\_\_\_  
Basin No. \_\_\_\_\_

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35770  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Leland Wallace DETAILED ADDRESS AT WELL LOCATION 23 E. Sandpiper Ln  
MAILING ADDRESS HG 72 Box 2200 Dyer, Nv. 89010  
Dyer, Nv. 89010 Subdivision Name: \_\_\_\_\_ County: Esmeralda

2. PLS LOCATION NE 1/4 NW 1/4 4 Sec 2 No 35 E Latitude 37° 48.101' UTM E \_\_\_\_\_  NAD 27  
PERMIT/WAIVER NO. 007-131-13 Longitude 118° 05.839' UTM N \_\_\_\_\_  NAD 83/WGS 84  
*Issued by Water Resources Current Parcel No.*

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  Auger  Rotary  RVC  
 Mining / Dewater  Com / Ind  Stock  Air  Mud  Sonic  
 Test / Other  Mun / QM  Rec  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
<u>silt sand</u>			<u>0</u>	<u>30</u>	
<u>gravel cobbler</u>			<u>30</u>	<u>70</u>	
<u>sand, fine gravel</u>			<u>70</u>	<u>160</u>	
<u>sandy clay</u>			<u>160</u>	<u>180</u>	
<u>sand, gravel</u>			<u>180</u>	<u>315</u>	

DCNR/DWR/SNBO  
RECEIVED  
JUN 06 2016

9. WELL CONSTRUCTION  
Depth Drilled: 315 Feet Depth Cased: 315 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 315 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>24</u>	<u>.280</u>	<u>0</u>	<u>15</u>
<u>6</u>		<u>SPR 17</u>	<u>15</u>	<u>315</u>

PERFORATIONS:  
Type of perforation: Screen  
Size of perforation: .032  
From 215 Feet To 315 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS

Sanitary Seal \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 5 to 60  Pumped  Poured  
 Bentonite Chips 0 to 5  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 15%  20%  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] 60 to 315  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: Oct. 6 20 15  
Date completed: Oct. 15 20 15

7. WATER QUALITIES  
Static water level: 124.1 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: Good

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air lift</u>	<u>250</u>		<u>4 hours</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Mr. Webber Drilling Contractor  
Address po Box 40 Overton, Nv. 890 Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 0025887  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2238  
Signed: Bryan Anzebre By driller performing actual drilling on site or contractor  
Date: Dec 30, 2015

(Rev. 08-12)  
(NSPO Rev 11-12)

USE ADDITIONAL SHEETS IF NECESSARY  
37,8017848  
-118.0962625  
NAD (0) 627 24