OFFICE USE ONLY
Log No. 125590
Permit No. 82096
Basin

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 35670

1. OWNER Howard Schroft Mary Cloud
MAILING ADDRESS PO Box 31 Moapa Nev 89025

ADDRESS AT WELL LOCATION 650 North Saltbrush Rd
Moapa NV 89025
County Clark
Subdivision 0
Latitude N36° 41.607'
Longitude W114° 40.881'
UTM E
N
☐ NAD 27 ☒ NAD 83 / WGS 84

2. LOCATION NW ¼ NE ¼ Sec 26 T 14 N R 65 E
PERMIT WAIVER No. 1030-26-81-005
Issued by Water Resources 82096
Parcel No.

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	70	70
Sand & boulders	X	70	125	55
Clay		125	131	6

7' of 8" steel casing was grouted over 6" PVC at surface
2" Inspection Port was welded on 8" steel at top of well

DCNR/DWR/SNBO
RECEIVED
JUN 07 2016

Date started: 5-27-2016, 20
Date completed: 6-1-2016, 20

7. Water Level
Static water level: 11 feet below land surface
Artesian Flow: 0 G.P.M. 0 P.S.I.
Water Temperature: Cool °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		2

9. WELL CONSTRUCTION
Depth Drilled 131 Feet Depth Cased 131 Feet

HOLE DIAMETER SIZE

		From	To
11	Inches	0 Feet	131 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6½	PVC	Sch 40	0	131

Perforation
Type of perforation saw cut
Size of perforation 1/8" X 3"
From 80 feet to 131 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 131 ☐ Pumped ☐ Poured
Type: 3/8 minus
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Hiko Nev 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 6-2-2016

USE ADDITIONAL SHEETS IF NECESSARY

36.6935562
-114.6805046
NAD 27

SPO 3-08