STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125603
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73890
WELL NAME *(If applicable)*: MW1

1. OWNER/CLIENT NAME Buyers Syndicate LC
MAILING ADDRESS 2733 E. Parleys Way Ste 300
Salt Lake City, UT 84109

DETAILED ADDRESS AT WELL LOCATION 1411 N. Eastern Ave.
Las Vegas, NV 89101
Subdivision Name: N/A *County:* Clark

2. PLS LOCATION NE¼ NE ¼ 26 Sec 20 N S 61 E
PERMIT/WAIVER NO. MD-3169 *Issued by Water Resources* 139-26-508-006 *Current Parcel No.*

Latitude 36° 11' 10.54" UTM E
Longitude -115° 07' 00.10" UTM N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dirt			0	10	10
Clay			10	27	17

DCNR/DWR/SNBO
RECEIVED
MAY 26 2016

Date started: 5/10 , 20 16
Date completed: 5/10 , 20 16

9. WELL CONSTRUCTION
Depth Drilled: 27 Feet Depth Cased: 27 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	27 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.682	.154	0	12

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: .020
From 12 Feet To 27 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☐ Sanitary Seal to
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ Bentonite Chips 0 to 10 ☐ Pumped ☒ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☒ Sand Pack [< 0.2 in.] 10 to 27 ☐ Pumped ☒ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 19 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: N/A ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
N/A			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Yellow Jacket Drilling Contractor
Address 3922 E. University Dr. Ste 1, Phoenix 8503 Contractor
Nevada contractor's license number as issued by the *State Contractor's Board*: 0058304A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2525
Signed: [signature] *By driller performing actual drilling on site or contractor*
Date: 5/20/16

(Rev. 08-12)
(NSPO Rev 11-12)
USE ADDITIONAL SHEETS IF NECESSARY
NAD 27 36.1862905 -115.1158603
(O) 627