STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125614
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37937
WELL NAME (If applicable): PMW-1

1. OWNER/CLIENT NAME: Mr Tedd Rosenstein Ellen 5 LLC
MAILING ADDRESS: 2500 W. Sahara Ave. # 211
Las Vegas, NV

DETAILED ADDRESS AT WELL LOCATION: 4002-4030 W.Charleston Blvd.
Las Vegas, NV
Subdivision Name: County: Clark

2. PLS LOCATION: SW ¼ SE ¼ 31 Sec 20 N/S 61 E
PERMIT/WAIVER NO. M03146 (Issued by Water Resources) 139-31-801-010 (Current Parcel No.)

Latitude: 36* 09' 33.35" N UTM E: ☐ NAD 27
Longitude: 115* 11' 42.19" W UTM N: ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	4"
TYPE II Fill			4"	1'
Caliche			1'	1.6"
White Sandy Lean clay w/ gravel			1.6"	5'
Very light re / brown silt w/gravel			5'	10'
Reddish brown lean clay w/silt			10'	15'
Reddish brown silty clay			15'	30'

DCNR/DWR/SNBO
RECEIVED
MAR 24 2016

Date started: 3-Mar, 20 16
Date completed: 3-Mar, 20 16

9. CONSTRUCTION
Depth Drilled: 30' Feet Depth Cased: 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8.25	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	20

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☑ Concrete Grout	0	to	1	☐ Pumped	☑ Poured
☑ Bentonite Chips	1	to	2	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	2	to	20	☐ Pumped	☑ Poured
☑ Other, explain: bent. chips	20	to	30	☐ Pumped	☑ Poured

PERFORATIONS
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
5	Feet	20	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 19' Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 4221 W. Oquendo Rd Las Vegas NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD
Signed: Bob H (By driller performing actual drilling on site or contractor)
Date: 3/23/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1592941
-115.194218