STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125617
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT No. 37941
WELL NAME (If applicable): IW-1

1. OWNER/CLIENT NAME: GB Nevada Real Estate LLC
MAILING ADDRESS: 3159 W. Buckeye Rd.
Pheonix AZ 85009-5636

DETAILED ADDRESS AT WELL LOCATION: 3873 S. Las Vegas Blvd
Las Vegas, NV
Subdivision Name: County: Clark

2. PLS LOCATION: SW ¼ NW ¼ 28 Sec 21 N(S) 61 E
PERMIT/WAIVER NO.: MO-3143 (Issued by Water Resources) 162-28-201-001 (Current Parcel No.)

Latitude: 36* 05' 49.05" N UTM E: ☑ NAD 27
Longitude: 115* 10' 20.06" W UTM N: ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	3"
Silty sand with gravels			3"	5'
yellowish-orange, fine sand				
, trace coarse-fine subangular				
gravel trace medium				
coarse sand				
Sitly,sand,yellowish orange			5'	
fine sand, trace coarse-fine				
gravel				17
Caliche			17'	30'
Clay with sand, light brn to light			30'	
grey,fine sand, trace fine gravel				
angular				34'

DCNR/DWR/SNBO
RECEIVED
MAR 21 2016

Date started: 18-Feb , 20 16
Date completed: 18-Feb , 20 16

7. WATER QUALITIES
Static water level: NA Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. CONSTRUCTION
Depth Drilled: 34 Feet Depth Cased: 34 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8.25 Inches		0 Feet	34 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.984	0.218	0	34

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☑ Cement Grout	5	to	17	☑ Pumped	☐ Poured
☑ Concrete Grout	5	to	1	☐ Pumped	☑ Poured
☑ Bentonite Chips	17	to	22	☐ Pumped	☑ Poured
☑ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☑ Poured
☑ Sand Pack [< 0.2 in.]	23	to	34	☐ Pumped	☑ Poured
☑ Other, explain:	22	to	23	☐ Pumped	☑ Poured

Seal # 0/30 Sand

PERFORATIONS
Type of perforation: Factory
Size of perforation: 0.02

From	To
24 Feet	34 Feet
Feet	Feet
Feet	Feet
Feet	Feet
Feet	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on site driller): 2512-LTD
Signed: Bob H (By driller performing actual drilling on site or contractor)
Date: 3/17/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.0969583
-115.172238
NAD 27