

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 125620
Permit No. _____
Basin No. _____

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT N 37941
WELL NAME (if applicable): IW-4

1. OWNER/CLIENT NAME GB Nevada Real Estate LLC
MAILING ADDRESS 3159 W. Buckeye Rd.
Phoenix AZ 85009-5636

DETAILED ADDRESS AT WELL LOCATION 3873 S. Las Vegas Blvd
Las Vegas, NV
Subdivision Name _____ County Clark

2. PLS LOCATION SW 1/4 NW 1/4 28 Sec 21 N/6 61 E
PERMIT/WAIVER NO. MO-3143 162-28-201-001
Issued by Water Resources Current Parcel No.

Latitude 36° 05' 49.87" N UTM E NAD 27
Longitude 115° 10' 19.92" W UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	4"
Silty sand with gravels yellowish-orange, fine sand trace coarse-fine subangular gravel trace medium coarse sand			4"	5'
Sandy silt, yellowish-orange fine sand			5'	10'
sand with silt and gravel yellowish-orange fine sand			10'	
sub angular gravel dense trace coarse sand				18
Caliche			18	19'
Silty sand light brown fine sand trace medium - coarse sand			19'	21'
Caliche			21'	29'
Clay with sand, light brown-white, fine sand, medium plasticity, trace medium to coarse sand, trace fine angular gravel			29'	34'

9. INSTRUCTION
Depth Drilled: 34 Feet Depth Cased: 34 Feet

HOLE DIAMETER (BIT SIZE)			
From	To	From	To
<u>8.25</u> Inches	<u>0</u> Feet	<u>34</u> Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.984</u>	<u>0.218</u>	<u>0</u>	<u>34</u>

ANNULAR MATERIALS
Sanitary Seal Yes No
 Neat Cement _____ to _____ Pumped Poured
 Cement Grout 5 to 17 Pumped Poured
 Concrete Grout 5 to 1 Pumped Poured
 Bentonite Chips 17 to 22 Pumped Poured
 Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 23 to 34 Pumped Poured
 Other, explain: 22 to 23 Pumped Poured
Sanitary Seal 0/30 sand

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02
From 24 Feet To 34 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

Date started 17-Feb, 20 16
Date completed 17-Feb, 20 16

7. WATER QUALITIES
Static water level: NA Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP Contractor
Address 5241 Schirlls St. Las Vegas, NV 89118 Contractor

8. WELL TEST DATA			
Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Nevada contractor's license number as issued by the State Contractor's Board 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller) 2512-LTD
Signed: Bob Zell
By driller performing actual drilling on site or contractor
Date: 3/17/2016

36,097,186 NAD
- 115,1722 27