WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125697
Permit No.
Basin

NOTICE OF INTENT NO. 39040

1. OWNER Jeff and Roxanna Cagle
MAILING ADDRESS 6361 S. Cajon Lane
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
6361 S. Cajon Lane 36D7'37.39"N -115D 58' 2.65W NAD83

2. LOCATION S/E 1/4 N/W 1/4 Sec. 13 T 21S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources | 44-592-25 Parcel No. | Conestoga Country Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
grey clay	x	122	131	9
grey caleche	x	131	145	14
light grey caleche	x	145	176	31
grey caleche	x	176	240	64

DCNR/DWR/SNBO
RECEIVED
AUG 01 2016

Date started 7/1/19~~16~~ 2016, 19__
Date completed 7/2/19~~16~~ 2016, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240+1 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7.5	Inches	122	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5.563	2.86	.265	0	240

Perforations:
Type perforation Factory Screen
Size perforation .032
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 122 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland
By driller performing actual drilling on site or contractor
Date 7.29.16

36.1270395 NAI
-115.9665461 27