WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 125691
Permit No.
Basin

NOTICE OF INTENT NO. 39053

1. OWNER Joe and Noreen McCaleb
MAILING ADDRESS 1960 E.Thorne Drive
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
1960 E. Thorne Drive 36D5'20.07" 115D 58'30.83"W NAD83

2. LOCATION S/E 1/4 S/E 1/4 Sec. 26 T 21S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources | 41-313-14 Parcel No. | Calvada Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown loam		0	18	18
brown caleche		18	21	3
See next line	x	21	210	189
brown loam with caleche strings				
gray gravel	x	210	220	10

DCNR/DWR/SNBO
RECEIVED
AUG 01 2016

Date started 7/7/1916 2016 , 19__
Date completed 7/7/1916 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 221 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches	0 Feet	220 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	220

Perforations:
Type perforation sawcut
Size perforation .188
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 220 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 61 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed Larry Strickland
By driller performing actual drilling on-site or contractor
Date 7.29.16

36.0889442
-115.9743746